



Product Service

CERTIFICATE

No. B 06 01 58274 001

Holder of Certificate: NeoSave Europe LimitedSuite 44, Vicarage House
58-60 Kensington Church Street
London
W8 4DB
UNITED KINGDOM**Production Facility(ies):** 51186**Certification Mark:****Product: Fluorescent Lamp Ballast
Electronic ballast EVG****Model(s): EVG SAVE T5 TRONIC**

Parameters:	Rated voltage:	220V - 240V
	Rated frequency:	50/60Hz
	Rated power:	35W
	Type of protection:	II
	Degree of (water) protection:	IP 20
	Remark:	Adapter System consists of three parts: EVG, Distaler and starter bridging

Tested according to: DIN EN 61347-2-3:2005
DIN EN 60400:2005
DIN EN 60598-1:2005

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. See also notes overleaf.

Test report no.: 70106110**Date,** 2006-01-13

Page 1 of 1

